

Processing Record for this file:
(Make notes here unique for this file)

Loading from 2014-03-01 - 2014-04-01

Data taken from DMF, untarred, unzipped and renamed back to original file names

It was noted that BOTH TEI 42i's began to lose their internal Mass Flow Meters. This was not consequential as the inlet has much better Mass Flow Controllers. The effect was noted as periodic drop outs and shifts in the internal MFM signals. The same behavior was noted in TCAP. It appears related to ingestion of water, though this is by no means definite.

NO₂ signal is problematic. The photolysis cell was only operating at ~10% efficiency for unknown reasons. Data is provided, but should be viewed circumspectly.

Data dropouts -

Power at T3 has been most irregular. The NO_x box in particular is susceptible to interruptions. After resumption of power, it takes time for the signals to stabilize (the PMT cooler takes some time to reach equilibrium). A log of data dropouts is as follows. Consult the site log for details.

2014-03-01 00:00 - 2014-03-02 17:29 MFC for the NO_y channel still in failure mode until replaced by Mentor. During this period NO is valid and NO₂ is reported but very uncertain.

2014-03-03 23:02 - 2014-03-04 14:41 Pumps off due to site power failure

2014-03-04 18:51 - 2014-03-04 23:29 Pumps off due to site power failure


2014-03-06 11:00 - 2014-03-06 14:00 NO exceeds NO_y. This is nonsensical.

2014-03-12 19:05 - 2014-03-13 13:36 Power off due to genset(?)

2014-03-16 17:57 - 2014-03-17 12:20 Power off due to genset(?)

Ground NO_x Analyzer Calibration Data


○ - NO Channel ; △ - NO_x Channel; □ - NO_y Channel
 Zero Air Equivalent Signal (ppbv)
 S.A. #1 (calibrated sig/dilution conc: [SA#1] = 20.8 ppbv)
 S.A. #2 (calibrated sig/dilution conc: [SA#2] = 82.86 ppbv)
 GPT + SA #2 (NO: frac titr., NO_x: Photol. C.E. (nom=0.1), NO_y: Mo C.E. (nom=1.03))
 HNO₃ cal. (calibrated sig/perme conc: [HNO₃] = 68.9 ppbv)



Project/Platform/Site: maomaoscs1
 ARM Climate Research Facility
 Contact: S.R. Springston (631) 344-4477, srs@bnl.gov

(UTC)


Ground-Based NO_x Analyzer
Housekeeping 1
Flows & Pressures




Project/Platform/Site: maomaoscs1
ARM Climate Research Facility
Contact: S.R. Springston (631) 344-4477, srs@bnl.gov

(UTC)


Ground-Based NO_x Analyzer Housekeeping 2 Temperatures




Ground NO_x Analyzer Parsed NOy Channel Data




Ground NO_x Analyzer Parsed NOx Channel Data




Ground NO_x Analyzer Parsed NO Channel Data



Calibration Factors Used:
NO: 1 ([calibrated]/[inst. reported])
NO₂: 1 ([calibrated]/[inst. reported]), C.E. = 0.1
NO_y: 1.1 ([calibrated]/[inst. reported]), C.E. = 1.03




Calibration Factors Used:
NO: 1 ([calibrated]/[inst. reported])
NO₂: 1 ([calibrated]/[inst. reported]), C.E. = 0.1
NO_y: 1.1 ([calibrated]/[inst. reported]), C.E. = 1.03




Project/Platform/Site: maomaoscs1
ARM Climate Research Facility
Contact: S.R. Springston (631) 344-4477, srs@bnl.gov


Calibration Factors Used:
NO: 1 ([calibrated]/[inst. reported])
NO₂: 1 ([calibrated]/[inst. reported]), C.E. = 0.1
NO_x: 1.1 ([calibrated]/[inst. reported]), C.E. = 1.03



Calibration Factors Used:
NO: 1 ([calibrated]/[inst. reported])
NO₂: 1 ([calibrated]/[inst. reported]), C.E. = 0.1
NO_y: 1.1 ([calibrated]/[inst. reported]), C.E. = 1.03



Calibration Factors Used:
NO: 1 ([calibrated]/[inst. reported])
NO₂: 1 ([calibrated]/[inst. reported]), C.E. = 0.1
NO_x: 1.1 ([calibrated]/[inst. reported]), C.E. = 1.03



Calibration Factors Used:
NO: 1 ([calibrated]/[inst. reported])
NO₂: 1 ([calibrated]/[inst. reported]), C.E. = 0.1
NO_y: 1.1 ([calibrated]/[inst. reported]), C.E. = 1.03

